



GVM TEST HOUSE
AND RESEARCH CENTRE

23-24, Yashodeep Heights,
Plot No. 14/15, Sector 29C,
Rabale-Ghansoli Node,
Navi Mumbai - 400 701, INDIA.
Phone: +91 93244 69890
Email: lab@gvmtesthouse.com
www.gvmtesthouse.com



TESTING | TRAINING | AUDITING

Report No.: GVM: WPS: 02229-1-1/10/2022
ULR: TC906122000001462F

Date: 20-10-2022
Page 1 of 1

AMCHEM PRODUCTS PVT. LTD.
98, Ecotech 12, Greater Noida
(West), 201306

TEST REPORT ON DRYTHANE ULTIMATE COMBINATION

Source of sample : Sample Submitted by Customer
Number of samples Tested : 01 (One Only).
Condition of sample : Satisfactory
Date of Receipt : 06.10.2022
Customer's Reference # : Request dated 06.10.2022
Lab Reference Number : 2022/OCT/02229-1-1
Material Identification # : Drythane Ultimate Combination
Period of Test : 06.10.2022 To 20.10.2022

TEST RESULTS:

S. N.	Test Conducted	Unit	Test Results	Test Method
1	Tensile Strength	N/mm ²	-	ASTM D-638 Type IV: 2016
2	Elongation	%	-	ASTM D-638 Type IV: 2016
3	Puncture Resistance	N	1015	ASTM E 154: 2008
4	Tear Strength	N/mm	29.8	ASTM D 624: 2020
5	Static Crack Bridging Ability	mm	13.1	EN 1062-7: 2004 (A)
6	Dynamic Crack Bridging Ability	Visual	No Crack	ASTM C 1305: 2016
7	Depth of Water Penetration	mm	Nil	EN 12390 -8: 2019
8	Resistance to Hydrostatic Head up to 7 Bar (71.4 meter)	Visual	Pass	ASTM D 5385:2020

As furnished by the customer.

- Note: 1. The Results relate only to the samples tested.
2. Report shall not be reproduced, except in full, without the written approval of the lab.
3. Any correction invalidates this report.

For GVM Test House And Research Centre



DINESH BURDE
[Signature]
Authorised Signatory





GVM TEST HOUSE
AND RESEARCH CENTRE

23-24, Yashodeep Heights,
Plot No. 14/15, Sector 29C,
Rabale-Ghansoli Node,
Navi Mumbai - 400 701, INDIA.
Phone: +91 93244 69890
Email: lab@gvmtesthouse.com
www.gvmtesthouse.com



ISO 9001:2015 Certified

TESTING | TRAINING | AUDITING

Report No.: GVM: WPS: 02229-1-2/10/2022

Date of Receipt: 06.10.2022

Date: 24-10-2022

Page 1 of 1

AMCHEM PRODUCTS PVT. LTD.

98, Ecotech 12, Greater Noida
(West), 201306

TEST REPORT ON DRYTHANE ULTIMATE COMBINATION

Source of sample : Sample Submitted by Customer
Number of samples Tested : 01 (One Only).
Condition of sample : Satisfactory
Date of Receipt : 06.10.2022
Customer's Reference # : Request dated 06.10.2022
Lab Reference Number : 2022/OCT/02229-1-2
Material Identification # : Drythane Ultimate Combination
Period of Test : 06.10.2022 To 24.10.2022

TEST RESULTS:

S. N.	Test Conducted	Unit	Test Results	Test Method
1	Water Absorption	%	0.1	ASTM D 570 : 2018
2	Water Vapour Transmission Rate	g/m ² /day	4.2	ASTM E 96 : 2000

As furnished by the customer.


- Note: 1. The Results relate only to the samples tested.
2. Report shall not be reproduced, except in full, without the written approval of the lab.
3. Any correction invalidates this report.

For GVM Test House And Research Centre



DINESH BURDE

Authorised Signatory



Regd. Office:

402, Yogesh Apartment CHS, Plot No. 26, Sector 8A, Airoli, Navi Mumbai - 400 708, INDIA.
GSTIN: 27BPBPB4090Q1ZM